


PLAN VIEW

GENERAL NOTES:


1. Concrete: 28 Day Compressive Strength $f'_c = 5,000$ psi
2. Rebar: Grade 60 Per ASTM A615 (Black).
3. Design Loading: AASHTO H-20. (2'-5" Cover)
4. General Contractor to Verify all Openings Sizes and Locations.
5. All Pipe and Roof Openings have Additional Rebar Reinforcement.
6. Joint to be Sealed with 1" Butyl Rubber.
7. All Hardware Shown But not Dimensioned is for Visual Reference Only-Do not Scale for Placement.

DATA CHART

LTR	QTY	Description
(A)	3	24" Dia. Cleanout
(B)	4	8" ϕ Knockout
(C)	8	Lifting Insert
(D)	4	Lifting Insert



ELEVATION VIEW



SIDE VIEW



ST 12000

FILE NAME: 325ESRST12000_DET.DWG

ISSUE DATE: January, 2008

www.oldcastleprecast.com

**7'-0" x 20'-6" x 12'-2" I.D.
Tank
12,000 Gallon Capacity
98,000 Lbs**

Copyright © 2008 Oldcastle Precast, Inc.